



## Sebewaing Light and Water Department

110 West Main Street  
P.O. Box 645  
Sebewaing, MI 48759  
Phone: (989) 883-2700 Fax: (989) 883-2792

### IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Sebewaing Light and Water (SLW) is required by the State of Michigan to monitor your drinking water for specific contaminants on a regular basis. These results are an indicator of whether or not our drinking water meets the current health standards. In 2024, from January 1 to September 30, the Radium 226 & 228 sample along with testing needed to be completed. SLW was notified of the missed test and completed the testing of Radium 226 & 228 on October 23, 2024. The test for Radium 226 & 228 passed. The State issued a violation due to the missed test deadline, however, this violation **does not** pose a threat to your water supply.

**What should I do?** As a community water supplier, we want to keep you informed of this situation and our corrective action. There is nothing you need to do at this time, and this situation is not an emergency.

The table below shows the missed contaminants, the frequency of the required test, the number of tests required and the time when the test should have been taken. We did this testing on October 23, 2024.

Regulated Contaminants	Required Sampling Frequency	Number Of Required Samples Taken	Time for Sampling	Date Missed Samples Will Be Taken
Radium 226/228	Every 6 Years	1	1/1/2024 to 9/30/2024	12/31/2024

**What happened? What is being done?** In 2024, we sampled all required contaminants highlighted but inadvertently missed the Radium 226/228 test. In an effort to correct this situation, our annual compliance requirements will be reviewed by at least two qualified water operators, including the Operator in Charge.

*For more information, please contact our office at 989.883.2700, 110 W Main St, Sebewaing, MI 48759, or via our email at [inquiry@slandw.com](mailto:inquiry@slandw.com)*

*Please share this information with individuals who drink this water, especially those who may not have received this notice directly.*